

CCIC Southern Testing Co., Ltd.

Attestation Of Conformity

CERTIFICATE NO.: SET2019-13364

Product: PV Grid Inverter

Model: MAC 70KTL3-X MV

Applicant: Shenzhen Growatt New EnergyTechnology Co.,LTD

1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28,

Address: GuangHui Road, LongTeng Community, Shiyan Street, Baoan District,

Shenzhen, P.R.China

This is to certify that, on the basis of the tests undertaken as per Report No. **SET2019-12713**, the submitted sample of the above item complies with:

EN 61000-6-2:2005 EN 61000-6-3:2007+A1:2011

and fulfils testing requirement of the EMC directive 2014/30/EU



Note: The model MAC 30KTL3-X LV、MAC 40KTL3-X LV、MAC 50KTL3-X LV、MAC 60KTL3-X LV、MAC 60KTL3-X LV、MAC 50KTL3-X MV、MAC 60KTL3-X MV、MAC 60KTL3-X MV、MAC 70KTL3-X MV only PV wire is different from other parts in hardware change. Consistently, the software modifies the current limit of the corresponding circuit. Among them, the software identifies different models by model, which limits different output power.

Signed for and on behalf of

CCIC Southern Testing Co., Ltd.

Shuarguen Zhang

Zhang Shuang wen, Manager

Date of Issue:Oct. 12.2019

CCIC Southern Testing Co., Ltd.

Electronic Testing Building, No. 43 Shahe Road, Xili Street, Nanshan District,

Shenzhen, 518055, P. R. China

Tel:86-0755-26627338 Fax:86-0755-26627238 http://www.ccic-set.com